

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing .

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

Test Sponsor : Wilsonart Australia
Unit 3B
13 - 15 Forrester Street
Kingsgrove NSW 2208

Test Number : 19-002987
Issue Date : 18/06/2019
Print Date : 11/07/2019

Sponsor Product Clients Ref : "Wilsonart (LPM)"
Timber effect laminated MDF
Colour : Various
End Use : Interior use, all joinery, walls, ceilings, furniture, doors and benchtops
Nominal Composition : Kraft paper, phenolic resin, MDF panel
Nominal Mass per Unit Area/Density : Approx 127g/m²
Nominal Thickness : 16mm

Product Group Number Classification : 3
Average Specific Extinction Area : 21.4 m²/kg



Fiona McDonald
Testing Technologist

36519

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. It's transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, it's disclosure or copying is prohibited . Please contact us by collect call so that arrangements can be made at our expense to rectify the error.