

Certificate of Assessment

NK5877

No 1237

"Copyright CSIRO 2009 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Halifax Vogel Group Pty Ltd
29 Henderson Street
TURRELLA NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 9384.

SAMPLE IDENTIFICATION: Creametal Gloss Magnetic Laminate


DESCRIPTION OF SAMPLE: The sponsor described the tested specimen as a melamine and iron foil laminate.

Nominal total thickness: 1 mm
Nominal mass: 2.75 kg/m²
Colour: White

SAMPLE CLASSIFICATION: Group Number: Group 3
(In accordance with Specification A2.4 of the Building Code of Australia.)
Average specific extinction area: 73.9 m²/kg
(Refer to Specification C1.10a section 3(c) of the Building Code of Australia.)

Testing Officer: Russell Collins Date of Test: 14 April 2009

Issued on the 15th day of April 2009 without alterations or additions.



Garry E Collins
Manager, Fire Testing and Assessments



CSIRO Materials Science and Engineering
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555